



TECHNICAL REPORT

Date of first issue: 2002-04-04	Project No.: 413 10297	DET NORSKE VERITAS CERTIFICATION AS <i>Testing, Product & Pers. Certification</i> Veritasveien 1 N-1322 HØVIK Norway Tel: +47 67 57 99 00 Fax: +47 67 57 89 60 http://www.dnv.com Org. No: NO 959 627 606 MVA
Approved by: Per Ove Øyberg Head of Section <i>Per Ove Øyberg</i>	Organisational unit: Testing, Product & Pers. Certification	
Client: SIXNET, Inc.	Client ref.: Dave Hoffman	

Summary:

Renamed to RemoteLog

Modules for control and measurement purposes from SIXNET, Inc. (SixTRAK, RemoteTRAK, VersaTRAK, EtherTRAK and SiteTRAK) has been EMC and environmentally tested in order to qualify for Type Approval in accordance with the DNV Standard for Certification No 2.4, April 2001. The tests were carried out in the Environmental Laboratory at Det Norske Veritas, Høvik, Norway between 2002-02-14 and 2002-03-21.

The system from SIXNET passed all the tests. During testing the units were installed inside a composite cabinet manufactured by Allied Moulded Products, OHIO, USA, part no. PJ-20168.

If the user wants to employ another type of cabinet (metallic, composite or other), this must have corresponding sealing properties (IP classification).

Revision 03:

- Module names changed from SIXTRAK, etc. to SixTRAK, etc.
- VersaTRAK added.

Report No.: 2002-3102	Subject Group:	
Report title: DNV Type Approval Testing of Modules for Control and Measurement Purposes		
Work carried out by: Line Gangeskar, Cecilie Gudesen Torp, Bjørn Kristoffersen, Per Gulbrandsen <i>Per Gulbrandsen</i>		
Work verified by: Steinar Andersen <i>Steinar Andersen</i>		
Date of this revision: 2003-03-03	Rev. No.: 03	Number of pages: 23

Indexing terms

ELECTROMAGNETIC COMPATIBILITY
 CLIMATIC TESTS
 MECHANICAL TESTS

- No distribution without permission from the client or responsible organisational unit, i.e. free distribution within DNV after 3 years
- Strictly confidential
- Unrestricted distribution



TECHNICAL REPORT

DET NORSKE VERITAS AS
Division Nordic Countries

Veritasveien 1,
N-1322 HØVIK, Norway
Tel: +47 67 57 99 00
Fax: +47 67 57 89 60
http://www.dnv.com
Org. No: NO 959 627 606 MVA

Date of first issue: 16 October 1998		Project No.: 510 7450
Approved by: <i>Magne Tørhaug</i> Magne Tørhaug Head of Department		Organisational unit: Test Laboratory
Client: SIXNET		Client ref.: Gary E. Lewis

Summary:

The SIXTRAK and VersaTRAK, both manufactured by SIXNET, have been environmentally tested in order to qualify for Type Approval by the Det Norske Veritas.

The tests were carried out according to the following specification:

- "Certification Notes No. 2.4, Environmental test specification for instrumentation and automation equipment", Det Norske Veritas AS, May 1995

The tests were carried out in the Environmental Laboratory at Det Norske Veritas, Høvik, Norway, between 30 March and 1 October 1998. With the modifications described in Chapter 4.4, the SIXTRAK and the VersaTRAK passed all the tests.

A summary of the results is given in Chapter 7 of the report.

Report No.: 98-1379	Subject Group: R1
Report title: Type testing of SIXTRAK and VersaTRAK	
Work carried out by: Amund Westin <i>Amund Westin</i>	
Work verified by: Per Gulbrandsen <i>Per Gulbrandsen</i>	
Date of this revision:	Rev. No.: 01
	Number of pages: 39

Indexing terms

Environmental Tests
Electromagnetic Compatibility
Type Approval

- No distribution without permission from the Client or responsible organisational unit
- Limited distribution within Det Norske Veritas
- Unrestricted distribution